

## Fire Classification of construction products and building elements

According to NEN EN 13501-1

Testnumber: 2018330069

Client: Recoat BV

Material: Recoat 2K products

Substrate: Powdercoated Stainless Steel

Product:	Article nr.	Classification according to NEN EN 13501-1
Recoat 2K Floor	88142	B - s1 d0
Recoat 2K Concrete	88252	B - s1 d0
Recoat 2K Semi Gloss	88462	B - s1 d0
Recoat 2K High Gloss	88672	B - s1 d0
Recoat 2K Anti Graffiti Mat	98352	B - s1 d0
Recoat 2K Anti Graffiti Semi Gloss	98562	B - s1 d0
Recoat 2K Anti Graffiti Gloss	98772	B - s1 d0

Date.....8 Aug 2018.....

Signature..........