SLIP TEST WORK SHEET

CUSTOMER NAME	Recoat UK Ltd
JOB No / TEST No	26012022
OPERATOR	Ian Roberts
DATE OF TEST	26th January 2022
ON SITE / LABORATORY	Laboratory
SLIP TESTER CALIBRATION No	CN 962
SLIP TESTER SERIAL No	ST 52
ROUGHNESS METER SERIAL No	N/A
SLIDER TYPE & CERTIFICATE No	3” Rubber slider 96. Cert No. 31/21. Batch No. 96#07
CONTAMINATE DESCRIPTION	Water
PAVIGRAVE TILE	KSS 1061 Expiry Date 30/06/2022

TEST LOCATION / MATERIAL DESCRIPTION (including customer ref)

Floor 2K – Slider 96

As Found

DIR A	1	2	3	4	5	6	7	8	MEAN
DRY	56	59	60	60	61	61	61	61	**61**
WET	49	51	54	54	55	55	55	55	**55**
DIR B	1	2	3	4	5	6	7	8	MEAN
DRY	59	60	60	60	60	60	60	59	**60**
WET	51	53	54	54	54	54	54	54	**54**
DIR C	1	2	3	4	5	6	7	8	MEAN
DRY	59	61	61	61	61	61	60	60	**61**
WET	53	54	54	55	55	55	55	54	**55**

AVERAGE DRY	**61**	**AVERAGE WET**	**55**

Machine / slider validated prior to test yes / no
Checked pointer / arm alignment yes / no.

Machine set level yes / no.
Pointer zero’d yes / no.

Slider conditioned yes/no
Set contact length yes / no